

ComAp's Statement

We, ComAp a.s., with its registered seat at U Uranie 1612/14a, 170 00 Praha 7, Czech Republic, ID 16188667, herewith declare that :

Description of the Unit: MainsPro[®] Mains Decoupling Protection Relay

Unit type: MainsPro ; MainsPro Lite

From Serial number : MainsPro :all ; MainsPro Lite :all

Applicable EC directives : Low Voltage Directive: **2014/35/EU**
EMC: **2014/30/EU**
VDE-AR-N **4105-2018**


Statement :

MainsPro is fulfilling the requirement of VDE-AR-N 4105:2018— the Chapter with Tripping times less then 100msec.
(Tabelle 2 – Einstellwerte für den NA-Schutz)

In Prague: October 24, 2018

Authorized Signature:

Marek Novotný
R&D Director



ComAp a.s.
U Uranie 1612/14a
170 00 Prague 7
Czech Republic

Tel.: +420 246 012 111
HotLine: +420 246 012 666
e-mail: info@comap-control.com
www.comap-control.com