

CE:16 – Declaration of Conformity

CE Declaration of Conformity According to Low Voltage Directive 2014/35/EU and Electromagnetic Compatibility Directive 2014/30/EU and Engineering Recommendation G59/3

We, ComAp a.s., with its registered seat at U Uranie 1612/14a, 170 00 Praha 7, Czech Republic, ID 16188667, herewith declare that the following item in our delivered version complies with the appropriate basic safety and health requirement of the Low Voltage Directive No.: 2014/35/EU and Electromagnetic Compatibility Directive 2014/30/EU and EMC standards as listed below as supplied. In case of alternation of the machine, not agreed upon by us, this declaration will lose its validity.

Description of the Unit: **Protection Relay for Parallel Applications**

Unit type: **InteliPRO Sync**

Extension modules: Relay card (default part of the unit)
IL-NT RS232 ; IL-NT RS232-485 ; IL-NT S-USB ; IB-Lite ;
IL-NT GPRS ; IC-NT-CT-BIO7 ; IG-IOM ; IGS-PTM ; IL-NT AIO

Applicable EC Directives: Low Voltage Directive: **2014/35/EU**
EMC: **2014/30/EU**
G59/3

Applicable Standards:


IEC 60255-21-1, IEC 60255-21-2 (No.of test report 304254-01/01),
IEC 61000-4 (selected parts), IEC 60255-22-1, IEC 60255-22-2, IEC 60255-22-3,
IEC 60255-22-4, IEC 60255-22-5, IEC 60255-22-6, IEC 60255-22-26
(No.of test report 102626-01/01), IEC 60255-5 (No.of test report 304139-01/01)

Responsible for:
Checking for correct application of the appropriate harmonized standards. The standard AR-N-4105 product InteliPRO Sync fulfill from the version 1.3

In Prague: December 8, 2016

Authorized Signature:

Marek Novotný
R&D Director



ComAp a.s.
U Uranie 1612/14a
170 00 Prague 7
Czech Republic

Tel.: +420 246 012 111
HotLine: +420 246 012 666
e-mail: info@comap.cz
www.comap.cz



Note:

The Low Voltage Directive requires that the last two digits of the year in which the CE marking was first affixed is given in the Declaration of Conformity.