

# Zertifikat

# Certificate



Zertifikat Nr. *Certificate No.*  
PV 50532127

Blatt *Sheet*  
0001

Ihr Zeichen *Client Reference*  
F.C.

Unser Zeichen *Our Reference*  
01-SYM-50092227 053

Ausstellungsdatum *Date of Issue*  
18.02.2022 (day/month/yr)

**Genehmigungsinhaber *License Holder***

Win Win Precision Technology  
Co., Ltd.  
4F., NO.180, Sec/2, Gongdao 5th Road  
East., Dist., Hsinchu City  
Taiwan, R.O.C.

**Fertigungsstätte *Manufacturing Plant***

040-0002146145

**Prüfzeichen *Test Mark***



**Geprüft nach *Tested acc. to***

IEC 61215-1:2016  
IEC 61215-1-1:2016  
IEC 61215-2:2016  
IEC 61730-1:2016  
IEC 61730-2:2016  
EN 61215-1:2016  
EN 61215-2:2017  
EN 61215-1-1:2016  
EN IEC 61730-1:2018  
EN IEC 61730-2:2018

**Zertifiziertes Produkt (Geräteidentifikation)  
*Certified Product (Product Identification)***

**Lizenzentgelte - Einheit  
*License Fee - Unit***

PV Module

**Type Designation:**

With 1/3 cut of mono c-Si cells:

WST-XXXMGX-E1 (XXX=390-415, in steps of 5, 108 cells)

WST-XXXMGX-E1 (XXX=520-550, in steps of 5, 144 cells)

WST-XXXMGT-E1 (XXX=590-610, in steps of 5, 120 cells)

WST-XXXMGT-E1 (XXX=645-675, in steps of 5, 132 cells)

**Remarks:**

Class II acc. to IEC 61140

Max. System Voltage: up to 1500 VDC (Voc at STC)

Fire Rating: Class C

Pollution Degree: 1

Design Load/ Safety Factors: 3600 Pa / 1.5 (downward)  
1600 Pa / 1.5 (upward)

**Conditions:**

The product test is voluntarily according to technical regulations. Any change of the design, materials, components or processing may require the repetition of some of the qualification tests in order to retain type approval.

The certificate is valid until 18 December 2022.

*Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde.  
Das Produkt entspricht den o.g. Anforderungen, die Herstellung wird überwacht.  
This certificate is based on our Testing and Certification Regulation. The product fulfills above mentioned requirements, the production is subject to surveillance.*

Zertifizierungsstelle

**TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg**

<http://www.tuv.com/safety> E-mail: [markcheck@tuv.com](mailto:markcheck@tuv.com)

Fax: +49 221 806-3935

